

R A D I O N I C S

D9124 Program Record Training Sheet

Date _____

Subscriber Name _____ Premises Phone _____

Address _____

City / State / ZIP _____

Installer Name _____ Subscriber Contact _____

Record Name _____

| Area Number | Account # | Area Description |
|-------------|-----------|---|
| 1 | _____ | The D9124 is programmed using the D9112B product handler program. The D9112B program loaded into the D9124 has been customized by Radionics so that it is better suited to fire alarm system installations using the D9124. |
| 2 | _____ | |
| 3 | _____ | This document contains the program entries that are loaded into new D9124 Addressable 24 volt Control/Communicators before they are shipped from the factory. |
| 4 | _____ | Radionics recommends that you copy the program from a new D9124 panel. Save and lock the copied program in your D5200 or RAM II. |
| 5 | _____ | Characters shown in <i>this type style</i> are used to indicate entries made using a "choice list" or the available character entries for a particular programming prompt. |
| 6 | _____ | |
| 7 | _____ | Bold characters in a Yes/No entry indicate the standard default in the D9112B product handler program. |
| 8 | _____ | Notice: While the factory loaded program may be well suited to a training environment, be sure to review ALL program entries and thoroughly test the alarm system before putting a panel in service. |

This Record Sheet contains the default entries in a D9124 "NEW RECORD"

Control/Communicator Location _____

Phone # _____ Aux Power Current Load _____ mA

AC Voltage _____ VAC Battery Voltage _____ VDC Earth Ground Location _____

Transformer Location _____ RJX38X _____

Bell / Siren Locations _____

Panel Wide Parameters

Phone

Phone # 1 -----
 Phone # 2 -----
 Phone # 3 -----
 Phone # 4 -----

| | | | |
|-----------------|----------|-------------------|--------------|
| Modem Format | Yes / No | Two Phone Lines | Yes / No |
| Point/User Flag | Yes / No | BFSK Duress Code | ----- |
| DTMF Dialing | Yes / No | Expanded Test Rpt | Yes / No |
| Phone Supv Time | ----- | Cancel Report | Yes / No |
| Alarm On Fail | Yes / No | Ground Start | Short / Long |

Phone Routing

| ▼ Report Type | Phone 1 | Phone 2 | Phone 3 | Phone 4 |
|----------------|---------|---------|---------|---------|
| Fire Alarm/Res | ----- | ----- | ----- | ----- |
| Fire Tbl/Res | ----- | ----- | ----- | ----- |
| Alarm/Res/Cncl | ----- | ----- | ----- | ----- |
| Trouble | ----- | ----- | ----- | ----- |
| Open/Close | ----- | ----- | ----- | ----- |
| Test/Stat Rpt | ----- | ----- | ----- | ----- |
| Diagnostic | ----- | ----- | ----- | ----- |
| Relay | ----- | ----- | ----- | ----- |
| Skeds | ----- | ----- | ----- | ----- |
| RAM | ----- | ----- | ----- | ----- |
| Power/Phone | ----- | ----- | ----- | ----- |
| Service | ----- | ----- | ----- | ----- |

Selections: Blank - Do not Send P - Primary B - Backup D - Duplicate

Power Supervision

| | | | |
|-----------------|-----------|------------------|----------|
| AC Fail Time | <u>15</u> | AC/Battery Buzz | Yes / No |
| AC Fail/Res Rpt | Yes / No | Bat Fail/Res Rpt | Yes / No |
| AC Tag Along | Yes / No | | |

Printer Parameters

| Printer Address | # 17 | # 18 | # 19 |
|-----------------|-------------------|-------------------|-------------------|
| Scope | <u>No Printer</u> | <u>No Printer</u> | <u>No Printer</u> |
| Area Assign | <u>1</u> | <u>1</u> | <u>1</u> |
| Supervision | Yes / No | Yes / No | Yes / No |
| Prt Points | Yes / No | Yes / No | Yes / No |
| Prt O/C | Yes / No | Yes / No | Yes / No |
| Prt Non Alarm | Yes / No | Yes / No | Yes / No |

Selections: No Printer Panel Wide Account Area

R.A.M. Parameters

| | | | |
|------------------|--------------------|-----------------|-------|
| RAM Passcode | <u>9 9 9 9 9 9</u> | Answer Armed | --- |
| Log % Full | --- | Answer Disarmed | --- |
| RAM Call Back | Yes / No | RAM Ph | ----- |
| RAM Line Monitor | Yes / No | | ----- |

Area Wide Parameters

Area Parameters

| | Area 1 | Area 2 | Area 3 | Area 4 | Area 5 | Area 6 | Area 7 | Area 8 |
|----------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|
| Area On | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No |
| Account Number | <u>0000</u> | <u>0000</u> | <u>0000</u> | <u>0000</u> | <u>0000</u> | <u>0000</u> | <u>0000</u> | <u>0000</u> |
| FA Bypass Max | <u>1</u> | <u>1</u> | <u>1</u> | <u>1</u> | <u>1</u> | <u>1</u> | <u>1</u> | <u>1</u> |
| Delay Res | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No |
| Exit Tone | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No |
| Exit Dly Time | <u>0</u> | <u>0</u> | <u>0</u> | <u>0</u> | <u>0</u> | <u>0</u> | <u>0</u> | <u>0</u> |
| Auto Watch | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No |
| Verify Time | <u>60</u> | <u>60</u> | <u>60</u> | <u>60</u> | <u>60</u> | <u>60</u> | <u>60</u> | <u>60</u> |

Verification Time: 10 - 60 Seconds

Bell Parameters

| | Area 1 | Area 2 | Area 3 | Area 4 | Area 5 | Area 6 | Area 7 | Area 8 |
|-------------|---------------|---------------|---------------|---------------|---------------|---------------|---------------|---------------|
| Fire Time | <u>6</u> | <u>6</u> | <u>6</u> | <u>6</u> | <u>6</u> | <u>6</u> | <u>6</u> | <u>6</u> |
| Fire Pat | <u>Steady</u> | <u>Steady</u> | <u>Steady</u> | <u>Steady</u> | <u>Steady</u> | <u>Steady</u> | <u>Steady</u> | <u>Steady</u> |
| Burg Time | <u>0</u> | <u>0</u> | <u>0</u> | <u>0</u> | <u>0</u> | <u>0</u> | <u>0</u> | <u>0</u> |
| Burg Pat | <u>Steady</u> | <u>Steady</u> | <u>Steady</u> | <u>Steady</u> | <u>Steady</u> | <u>Steady</u> | <u>Steady</u> | <u>Steady</u> |
| Single Ring | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No |
| Bell Test | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No |

Pattern Selections: Steady Pulse March Time CA Standard Temporal Code 3

Opening & Closing

Open/Close Options

| | Area 1 | Area 2 | Area 3 | Area 4 | Area 5 | Area 6 | Area 7 | Area 8 |
|-----------------------|----------|----------|----------|----------|----------|----------|----------|----------|
| Acct O/C | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No |
| Area O/C | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No |
| Restrictd O/C | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No |
| Perimeter O/C | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No |
| Disable O/C In Window | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No |
| Auto Close | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No |
| Fail To Open | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No |
| Fail To Close | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No |

O/C Windows

| Day of Week | Sched # | Open | | | Sched # | Close | | | Xept Holiday | Holiday | Area(s) |
|-------------|---------|-------------|--------------|------|---------|-------------|--------------|------|--------------|---------|-----------------|
| | | Early Begin | Window Start | Stop | | Early Begin | Window Start | Stop | | | |
| 1 | SMTWTFS | 18 | --- | --- | 19 | --- | --- | --- | Yes / No | 1 2 3 4 | 1 2 3 4 5 6 7 8 |
| 2 | SMTWTFS | 20 | --- | --- | 21 | --- | --- | --- | Yes / No | 1 2 3 4 | 1 2 3 4 5 6 7 8 |
| 3 | SMTWTFS | 22 | --- | --- | 23 | --- | --- | --- | Yes / No | 1 2 3 4 | 1 2 3 4 5 6 7 8 |
| 4 | SMTWTFS | 24 | --- | --- | 25 | --- | --- | --- | Yes / No | 1 2 3 4 | 1 2 3 4 5 6 7 8 |
| 5 | SMTWTFS | 26 | --- | --- | 27 | --- | --- | --- | Yes / No | 1 2 3 4 | 1 2 3 4 5 6 7 8 |
| 6 | SMTWTFS | 28 | --- | --- | 29 | --- | --- | --- | Yes / No | 1 2 3 4 | 1 2 3 4 5 6 7 8 |
| 7 | SMTWTFS | 30 | --- | --- | 31 | --- | --- | --- | Yes / No | 1 2 3 4 | 1 2 3 4 5 6 7 8 |
| 8 | SMTWTFS | 32 | --- | --- | 33 | --- | --- | --- | Yes / No | 1 2 3 4 | 1 2 3 4 5 6 7 8 |
| 9 | SMTWTFS | 34 | --- | --- | 35 | --- | --- | --- | Yes / No | 1 2 3 4 | 1 2 3 4 5 6 7 8 |
| 10 | SMTWTFS | 36 | --- | --- | 37 | --- | --- | --- | Yes / No | 1 2 3 4 | 1 2 3 4 5 6 7 8 |
| 11 | SMTWTFS | 38 | --- | --- | 39 | --- | --- | --- | Yes / No | 1 2 3 4 | 1 2 3 4 5 6 7 8 |
| 12 | SMTWTFS | 40 | --- | --- | 41 | --- | --- | --- | Yes / No | 1 2 3 4 | 1 2 3 4 5 6 7 8 |
| 13 | SMTWTFS | 42 | --- | --- | 43 | --- | --- | --- | Yes / No | 1 2 3 4 | 1 2 3 4 5 6 7 8 |
| 14 | SMTWTFS | 44 | --- | --- | 45 | --- | --- | --- | Yes / No | 1 2 3 4 | 1 2 3 4 5 6 7 8 |
| 15 | SMTWTFS | 46 | --- | --- | 47 | --- | --- | --- | Yes / No | 1 2 3 4 | 1 2 3 4 5 6 7 8 |
| 16 | SMTWTFS | 48 | --- | --- | 49 | --- | --- | --- | Yes / No | 1 2 3 4 | 1 2 3 4 5 6 7 8 |

All windows start at midnight.

Command Center

Cmd Cntr Assignment

| Address | Supervised | Scope | Area |
|----------------|------------|-----------|------|
| Cmd Center # 1 | Yes / No | Area | 1 |
| Cmd Center # 2 | Yes / No | No Keypad | 1 |
| Cmd Center # 3 | Yes / No | No Keypad | 1 |
| Cmd Center # 4 | Yes / No | No Keypad | 1 |
| Cmd Center # 5 | Yes / No | No Keypad | 1 |
| Cmd Center # 6 | Yes / No | No Keypad | 1 |
| Cmd Center # 7 | Yes / No | No Keypad | 1 |
| Cmd Center # 8 | Yes / No | No Keypad | 1 |

Selections = No Keypad / Panel Wide / Account / Area

Area Text

| | Area 1 | Area 2 |
|-------------------|-----------------------|--------|
| Area # Is On | PRESS - ALARM SILENCE | ----- |
| Area # Not Ready | CHECK - FIRE SYS | ----- |
| Area # Is Off | * - FIRE SYSTEM * | ----- |
| Area # Acct is On | ----- | ----- |
| | Area 3 | Area 4 |
| Area # Is On | ----- | ----- |
| Area # Not Ready | ----- | ----- |
| Area # Is Off | ----- | ----- |
| Area # Acct is On | ----- | ----- |
| | Area 5 | Area 6 |
| Area # Is On | ----- | ----- |
| Area # Not Ready | ----- | ----- |
| Area # Is Off | ----- | ----- |
| Area # Acct is On | ----- | ----- |
| | Area 7 | Area 8 |
| Area # Is On | ----- | ----- |
| Area # Not Ready | ----- | ----- |
| Area # Is Off | ----- | ----- |
| Area # Acct is On | ----- | ----- |

Custom Function

| Text | Key Strokes |
|--------------------------|-------------|
| CF 128 ALARM SILENCE? | 125600E |
| CF 129 TROUBLE SILENCE? | A4C |
| CF 130 DETECTOR RESET? | A47 |
| CF 131 ANNUNCIATOR RESET | 125600C |
| CF 132 | ----- |
| CF 133 | ----- |
| CF 134 | ----- |
| CF 135 | ----- |
| CF 136 | ----- |
| CF 137 | ----- |
| CF 138 | ----- |
| CF 139 | ----- |
| CF 140 | ----- |
| CF 141 | ----- |
| CF 142 | ----- |
| CF 143 | ----- |

| | |
|-------------|----------|
| 0-9 = 0-9 | C = ESC |
| A = COMMAND | D = NEXT |
| B = PREV | E = ENT |

User Interface

| Cmd Center Function | | | | Authority Level Selections | | | | | | | | | | | | | | |
|--|-----------------|-----------|-----|-------------------------------|---|---|---|---|---|---|---|---|----|----|----|----|----|----|
| | | | | Blank = Disabled / E = Enable | | | | | | | | | | | | | | |
| Blank = Disabled / E = Enable / P = Passcode | | | | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 | 11 | 12 | 13 | 14 | 15 |
| # | Function | Command | E/P | | | | | | | | | | | | | | | |
| 1 | Disarm | | P | | | | | | | | | | | | | | | |
| 2 | Master Arm | CMD 1 | | | | | | | | | | | | | | | | |
| 3 | Mstr Arm Inst | CMD 11 | | | | | | | | | | | | | | | | |
| 4 | Perim Inst | CMD 2 | | | | | | | | | | | | | | | | |
| 5 | Perim Delay | CMD 3 | | | | | | | | | | | | | | | | |
| 6 | Watch Mode | CMD 6 | | | | | | | | | | | | | | | | E |
| 7 | Perim Partial | CMD 8 | | | | | | | | | | | | | | | | |
| 8 | View Area Stat | | | | | | | | | | | | | | | | | E |
| 9 | View Event Mem | CMD 40 | E | | | | | | | | | | | | | | | E |
| 10 | View Pt Status | | E | | | | | | | | | | | | | | | E |
| 11 | Walk Test | CMD 44 | | | | | | | | | | | | | | | | E |
| 12 | Fire Test | CMD 58 | E | | | | | | | | | | | | | | | E |
| 13 | Send Report | CMD 41/42 | | | | | | | | | | | | | | | | E |
| 14 | Not Used | | | | | | | | | | | | | | | | | |
| 15 | Chg Display | CMD 49 | | | | | | | | | | | | | | | | E |
| 16 | Chg Time/Date | CMD 45 | E | | | | | | | | | | | | | | | E |
| 17 | Chg Passcode | CMD 55 | | | | | | | | | | | | | | | | E |
| 18 | Add Passcode | CMD 56 | | | | | | | | | | | | | | | | |
| 19 | Del Passcode | CMD 53 | | | | | | | | | | | | | | | | E |
| 20 | Extend Close | CMD 51 | | | | | | | | | | | | | | | | E |
| 21 | View Log | | E | | | | | | | | | | | | | | | E |
| 22 | Print Log | | | | | | | | | | | | | | | | | E |
| 23 | User Cmd 7 | CMD 7 | | | | | | | | | | | | | | | | E |
| 24 | User Cmd 9 | CMD 9 | | | | | | | | | | | | | | | | E |
| 25 | Bypass a Pt | CMD 0 | E | | | | | | | | | | | | | | | |
| 26 | Unbypas a Pt | CMD 00 | E | | | | | | | | | | | | | | | E |
| 27 | Reset Sensors | CMD 47 | | | | | | | | | | | | | | | | E |
| 28 | Relay Control | CMD 54 | | | | | | | | | | | | | | | | E |
| 29 | Remote Program | CMD 43 | E | | | | | | | | | | | | | | | E |
| 30 | Move to Area | CMD 50 | | | | | | | | | | | | | | | | E |
| 31 | Not Used | | | | | | | | | | | | | | | | | |
| 32 | Display Rev | CMD 59 | E | | | | | | | | | | | | | | | E |
| 33 | Service Walk | | | | | | | | | | | | | | | | | E |
| 34 | Default Text | CMD 57 | E | | | | | | | | | | | | | | | E |
| 35 | Change Skeds | CMD 52 | | | | | | | | | | | | | | | | E |
| | Force Arm | | P | | | | | | | | | | | | | | | |
| | Area O/C | | P | | | | | | | | | | | | | | | |
| | Restricted O/C | | P | | | | | | | | | | | | | | | |
| | Perimeter O/C | | P | | | | | | | | | | | | | | | |
| | Send Duress | | P | | | | | | | | | | | | | | | |
| | Passcode Arm | | P | | | | | | | | | | | | | | | |
| | Passcode Disarm | | P | | | | | | | | | | | | | | | E |

Command Menu

| Menu Item | Function | CC Address 1 | CC Address 2 | CC Address 3 | CC Address 4 | CC Address 5 | CC ADDRESS 6 | CC Address 7 | CC Address 8 |
|-----------|------------|--------------|--------------|--------------|--------------|--------------|--------------|--------------|--------------|
| 1 | <u>128</u> | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No |
| 2 | <u>129</u> | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No |
| 3 | <u>130</u> | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No |
| 4 | <u>131</u> | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No |
| 5 | <u>9</u> | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No |
| 6 | <u>10</u> | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No |
| 7 | <u>12</u> | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No |
| 8 | <u>21</u> | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No |
| 9 | <u>29</u> | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No |
| 10 | <u>32</u> | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No |
| 11 | --- | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No |
| 12 | --- | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No |
| 13 | --- | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No |
| 14 | --- | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No |
| 15 | --- | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No |
| 16 | --- | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No |
| 17 | --- | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No |
| 18 | --- | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No |
| 19 | --- | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No |
| 20 | --- | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No |
| 21 | --- | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No |
| 22 | --- | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No |
| 23 | --- | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No |
| 24 | --- | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No |
| 25 | --- | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No |
| 26 | --- | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No |
| 27 | --- | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No |
| 28 | --- | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No |
| 29 | --- | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No |
| 30 | --- | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No |
| 31 | --- | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No |
| 32 | --- | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No | Yes / No |

User Access Windows

| Sked # | User Window # | Day of Week | Access Window | | Kept Holiday | Holiday |
|--------|---------------|---------------|---------------|------|--------------|---------|
| | | | Start | Stop | | |
| 50 | 1 | S M T W T F S | -- | -- | Yes / No | 1 2 3 4 |
| 51 | 2 | S M T W T F S | -- | -- | Yes / No | 1 2 3 4 |
| 52 | 3 | S M T W T F S | -- | -- | Yes / No | 1 2 3 4 |
| 53 | 4 | S M T W T F S | -- | -- | Yes / No | 1 2 3 4 |
| 54 | 5 | S M T W T F S | -- | -- | Yes / No | 1 2 3 4 |
| 55 | 6 | S M T W T F S | -- | -- | Yes / No | 1 2 3 4 |
| 56 | 7 | S M T W T F S | -- | -- | Yes / No | 1 2 3 4 |
| 57 | 8 | S M T W T F S | -- | -- | Yes / No | 1 2 3 4 |
| 58 | 9 | S M T W T F S | -- | -- | Yes / No | 1 2 3 4 |
| 59 | 10 | S M T W T F S | -- | -- | Yes / No | 1 2 3 4 |
| 60 | 11 | S M T W T F S | -- | -- | Yes / No | 1 2 3 4 |
| 61 | 12 | S M T W T F S | -- | -- | Yes / No | 1 2 3 4 |
| 62 | 13 | S M T W T F S | -- | -- | Yes / No | 1 2 3 4 |
| 63 | 14 | S M T W T F S | -- | -- | Yes / No | 1 2 3 4 |
| 64 | 15 | S M T W T F S | -- | -- | Yes / No | 1 2 3 4 |

| | | | | |
|--------------------|-----|-----|-----|-----|
| DOW Only | Yes | Yes | No | No |
| DOW Except Holiday | Yes | Yes | Yes | Yes |
| DOW Plus Holiday | Yes | Yes | No | Yes |
| Holiday Only | No | Yes | No | Yes |

All windows start at midnight.

Passcode Worksheet

Duress _____ Selections: 1 or 2

| User Flag | User | Passcode | User Window | Area Auth | | | | | | | | User Name | |
|-----------|------|-------------|-------------|-----------|----|----|----|----|----|----|----|-----------|------------------|
| | | | | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | | |
| 000 | 00 | _____ | --- | 15 | 15 | 15 | 15 | 15 | 15 | 15 | 15 | 15 | Service Passcode |
| 001 | 01 | 1 2 5 6 0 0 | --- | 14 | | | | | | | | | |
| 002 | 02 | _____ | --- | | | | | | | | | | |
| 003 | 03 | _____ | --- | | | | | | | | | | |
| 004 | 04 | _____ | --- | | | | | | | | | | |
| 005 | 05 | _____ | --- | | | | | | | | | | |
| 601 | 06 | _____ | --- | | | | | | | | | | |
| 602 | 07 | _____ | --- | | | | | | | | | | |
| 603 | 08 | _____ | --- | | | | | | | | | | |
| 604 | 09 | _____ | --- | | | | | | | | | | |
| 605 | 10 | _____ | --- | | | | | | | | | | |
| 606 | 11 | _____ | --- | | | | | | | | | | |
| 607 | 12 | _____ | --- | | | | | | | | | | |
| 608 | 13 | _____ | --- | | | | | | | | | | |
| 701 | 14 | _____ | --- | | | | | | | | | | |
| 702 | 15 | _____ | --- | | | | | | | | | | |
| 703 | 16 | _____ | --- | | | | | | | | | | |
| 704 | 17 | _____ | --- | | | | | | | | | | |
| 705 | 18 | _____ | --- | | | | | | | | | | |
| 706 | 19 | _____ | --- | | | | | | | | | | |
| 707 | 20 | _____ | --- | | | | | | | | | | |
| 708 | 21 | _____ | --- | | | | | | | | | | |
| 801 | 22 | _____ | --- | | | | | | | | | | |
| 802 | 23 | _____ | --- | | | | | | | | | | |
| 803 | 24 | _____ | --- | | | | | | | | | | |
| 804 | 25 | _____ | --- | | | | | | | | | | |
| 805 | 26 | _____ | --- | | | | | | | | | | |
| 806 | 27 | _____ | --- | | | | | | | | | | |
| 807 | 28 | _____ | --- | | | | | | | | | | |
| 808 | 29 | _____ | --- | | | | | | | | | | |
| B01 | 30 | _____ | --- | | | | | | | | | | |
| B02 | 31 | _____ | --- | | | | | | | | | | |
| B03 | 32 | _____ | --- | | | | | | | | | | |
| B04 | 33 | _____ | --- | | | | | | | | | | |
| B05 | 34 | _____ | --- | | | | | | | | | | |
| B06 | 35 | _____ | --- | | | | | | | | | | |
| B07 | 36 | _____ | --- | | | | | | | | | | |
| B08 | 37 | _____ | --- | | | | | | | | | | |
| C01 | 38 | _____ | --- | | | | | | | | | | |
| C02 | 39 | _____ | --- | | | | | | | | | | |
| C03 | 40 | _____ | --- | | | | | | | | | | |
| C04 | 41 | _____ | --- | | | | | | | | | | |
| C05 | 42 | _____ | --- | | | | | | | | | | |
| C06 | 43 | _____ | --- | | | | | | | | | | |
| C07 | 44 | _____ | --- | | | | | | | | | | |
| C08 | 45 | _____ | --- | | | | | | | | | | |
| D01 | 46 | _____ | --- | | | | | | | | | | |
| D02 | 47 | _____ | --- | | | | | | | | | | |
| D03 | 48 | _____ | --- | | | | | | | | | | |
| D04 | 49 | _____ | --- | | | | | | | | | | |

Passcode Worksheet Cont.

| User Flag | User | Passcode | User Window | Area Auth | | | | | | | | User Name |
|-----------|------|----------|-------------|-----------|-----|-----|-----|-----|-----|-----|-----|-----------|
| | | | | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | |
| D05 | 50 | ----- | --- | --- | --- | --- | --- | --- | --- | --- | --- | |
| D06 | 51 | ----- | --- | --- | --- | --- | --- | --- | --- | --- | --- | |
| D07 | 52 | ----- | --- | --- | --- | --- | --- | --- | --- | --- | --- | |
| D08 | 53 | ----- | --- | --- | --- | --- | --- | --- | --- | --- | --- | |
| E01 | 54 | ----- | --- | --- | --- | --- | --- | --- | --- | --- | --- | |
| E02 | 55 | ----- | --- | --- | --- | --- | --- | --- | --- | --- | --- | |
| E03 | 56 | ----- | --- | --- | --- | --- | --- | --- | --- | --- | --- | |
| E04 | 57 | ----- | --- | --- | --- | --- | --- | --- | --- | --- | --- | |
| E05 | 58 | ----- | --- | --- | --- | --- | --- | --- | --- | --- | --- | |
| E06 | 59 | ----- | --- | --- | --- | --- | --- | --- | --- | --- | --- | |
| E07 | 60 | ----- | --- | --- | --- | --- | --- | --- | --- | --- | --- | |
| E08 | 61 | ----- | --- | --- | --- | --- | --- | --- | --- | --- | --- | |
| F01 | 62 | ----- | --- | --- | --- | --- | --- | --- | --- | --- | --- | |
| F02 | 63 | ----- | --- | --- | --- | --- | --- | --- | --- | --- | --- | |
| F03 | 64 | ----- | --- | --- | --- | --- | --- | --- | --- | --- | --- | |
| F04 | 65 | ----- | --- | --- | --- | --- | --- | --- | --- | --- | --- | |
| F05 | 66 | ----- | --- | --- | --- | --- | --- | --- | --- | --- | --- | |
| F06 | 67 | ----- | --- | --- | --- | --- | --- | --- | --- | --- | --- | |
| F07 | 68 | ----- | --- | --- | --- | --- | --- | --- | --- | --- | --- | |
| F08 | 69 | ----- | --- | --- | --- | --- | --- | --- | --- | --- | --- | |
| 000 | 70 | ----- | --- | --- | --- | --- | --- | --- | --- | --- | --- | |
| 000 | 71 | ----- | --- | --- | --- | --- | --- | --- | --- | --- | --- | |
| 000 | 72 | ----- | --- | --- | --- | --- | --- | --- | --- | --- | --- | |
| 000 | 73 | ----- | --- | --- | --- | --- | --- | --- | --- | --- | --- | |
| 000 | 74 | ----- | --- | --- | --- | --- | --- | --- | --- | --- | --- | |
| 000 | 75 | ----- | --- | --- | --- | --- | --- | --- | --- | --- | --- | |
| 000 | 76 | ----- | --- | --- | --- | --- | --- | --- | --- | --- | --- | |
| 000 | 77 | ----- | --- | --- | --- | --- | --- | --- | --- | --- | --- | |
| 000 | 78 | ----- | --- | --- | --- | --- | --- | --- | --- | --- | --- | |
| 000 | 79 | ----- | --- | --- | --- | --- | --- | --- | --- | --- | --- | |
| 000 | 80 | ----- | --- | --- | --- | --- | --- | --- | --- | --- | --- | |
| 000 | 81 | ----- | --- | --- | --- | --- | --- | --- | --- | --- | --- | |
| 000 | 82 | ----- | --- | --- | --- | --- | --- | --- | --- | --- | --- | |
| 000 | 83 | ----- | --- | --- | --- | --- | --- | --- | --- | --- | --- | |
| 000 | 84 | ----- | --- | --- | --- | --- | --- | --- | --- | --- | --- | |
| 000 | 85 | ----- | --- | --- | --- | --- | --- | --- | --- | --- | --- | |
| 000 | 86 | ----- | --- | --- | --- | --- | --- | --- | --- | --- | --- | |
| 000 | 87 | ----- | --- | --- | --- | --- | --- | --- | --- | --- | --- | |
| 000 | 88 | ----- | --- | --- | --- | --- | --- | --- | --- | --- | --- | |
| 000 | 89 | ----- | --- | --- | --- | --- | --- | --- | --- | --- | --- | |
| 000 | 90 | ----- | --- | --- | --- | --- | --- | --- | --- | --- | --- | |
| 000 | 91 | ----- | --- | --- | --- | --- | --- | --- | --- | --- | --- | |
| 000 | 92 | ----- | --- | --- | --- | --- | --- | --- | --- | --- | --- | |
| 000 | 93 | ----- | --- | --- | --- | --- | --- | --- | --- | --- | --- | |
| 000 | 94 | ----- | --- | --- | --- | --- | --- | --- | --- | --- | --- | |
| 000 | 95 | ----- | --- | --- | --- | --- | --- | --- | --- | --- | --- | |
| 000 | 96 | ----- | --- | --- | --- | --- | --- | --- | --- | --- | --- | |
| 000 | 97 | ----- | --- | --- | --- | --- | --- | --- | --- | --- | --- | |
| 000 | 98 | ----- | --- | --- | --- | --- | --- | --- | --- | --- | --- | |
| 000 | 99 | 125600 | --- | 14 | --- | --- | --- | --- | --- | --- | --- | |

Point Index

| Point Index Number | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 | 11 | 12 | 13 | 14 | 15 |
|-----------------------------|------------|------------|------------|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|
| Type (0-7) | <u>1</u> | — | — | — | — | — | — | — | — | — | — | — | — | — | — |
| Pt Response (0-D) | <u>3</u> | — | — | — | — | — | — | — | — | — | — | — | — | — | — |
| Entry Delay (5-600) | <u>5</u> | — | — | — | — | — | — | — | — | — | — | — | — | — | — |
| Entry Tone Off | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N |
| | | | | | | | | | | | | | | | |
| Silent Bell | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N |
| Ring Until Restored | <u>Y/N</u> | <u>Y/N</u> | <u>Y/N</u> | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N |
| Audible After 2 Failures | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N |
| Invisible | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N |
| Buzz on Fault | <u>Y/N</u> | <u>Y/N</u> | <u>Y/N</u> | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N |
| Watch Point | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N |
| Relay Follows Point | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N |
| | | | | | | | | | | | | | | | |
| Local While Disarmed | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N |
| Local While Armed | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N |
| Disable Restorals | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N |
| Returnable | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N |
| | | | | | | | | | | | | | | | |
| Bypassable | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N |
| Swinger Bypass | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N |
| Report Bypass at Occurrence | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N |
| Defer Bypass Report | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N |
| | | | | | | | | | | | | | | | |
| Fire Point | <u>Y/N</u> | <u>Y/N</u> | <u>Y/N</u> | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N |
| Alarm Verify | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N |
| Resettable | Y/N | Y/N | <u>Y/N</u> | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N |

Type Selections:

| | |
|---------------|--------------------------|
| 0 = 24 Hour | 4 = Keyswitch Maintained |
| 1 = Perimeter | 5 = Keyswitch Momentary |
| 2 = Interior | 6 = O/C Point |
| 3 = Follower | 7 = D279 |

Point Index cont.

| Point Index Number | 16 | 17 | 18 | 19 | 20 | 21 | 22 | 23 | 24 | 25 | 26 | 27 | 28 | 29 | 30 | 31 |
|----------------------------|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|
| Type (0-7) | — | — | — | — | — | — | — | — | — | — | — | — | — | — | — | — |
| Pt Response (0-D) | — | — | — | — | — | — | — | — | — | — | — | — | — | — | — | — |
| Entry Delay (5-600) | — | — | — | — | — | — | — | — | — | — | — | — | — | — | — | — |
| Entry Tone Off | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N |
| | | | | | | | | | | | | | | | | |
| Silent Bell | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N |
| Ring Until Restored | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N |
| Audible After 2 Failures | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N |
| Invisible Point | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N |
| Buzz on Fault | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N |
| Watch Point | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N |
| Relay Follows Point | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N |
| | | | | | | | | | | | | | | | | |
| Local While Disarmed | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N |
| Local While Armed | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N |
| Disable Restorals | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N |
| Returnable | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N |
| | | | | | | | | | | | | | | | | |
| Bypassable | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N |
| Swinger Bypass | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N |
| Report Bypass at Occurence | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N |
| Defer Bypass Report | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N |
| | | | | | | | | | | | | | | | | |
| Fire Point | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N |
| Alarm Verify | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N |
| Resettable | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N | Y/N |

Point Response Selections (I = Instant D = Delay T = Trouble)

| | | 0 | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | A | B | C | D | |
|------------|-------|-------|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Controlled | Armed | Open | I | I | I | I | D | D | I | I | D | I | I | I | I | I |
| | | Short | I | I | I | I | I | I | D | D | D | I | I | I | I | I |
| Disarmed | Open | | T | | T | | | | T | | I | I | T | I | | |
| | | Short | | | T | T | | T | | | I | T | I | | I | |
| 24 Hour | Open | I | T | I | T | | | I | T | | | | | | | |
| | | Short | I | I | T | T | I | T | | | | | | | | |

Point Assignments

| Poplt Switch Setting | Translation | Point # | Point Index | Area Assign | Debounce | BFSK/ Relay | Point Text |
|----------------------|-------------|---------|-------------|-------------|----------|-------------|----------------------------------|
| | 100 | 01 | --- | --- | --- | --- | ----- |
| | 200 | 02 | --- | --- | --- | --- | ----- |
| | 300 | 03 | --- | --- | --- | --- | ----- |
| | 400 | 04 | --- | --- | --- | --- | ----- |
| | 500 | 05 | --- | --- | --- | --- | ----- |
| | 600 | 06 | --- | --- | --- | --- | ----- |
| | 700 | 07 | <u>1</u> | <u>1</u> | --- | --- | <u>I N D I C A T I N G C K T</u> |
| | 800 | 08 | <u>1</u> | <u>1</u> | --- | --- | <u>2 4 V P O W E R C K T</u> |
| 123456 | 101 | 09 | --- | --- | --- | --- | ----- |
| 1234 5- | 102 | 10 | --- | --- | --- | --- | ----- |
| 1234 -6 | 103 | 11 | --- | --- | --- | --- | ----- |
| 1234 -- | 104 | 12 | --- | --- | --- | --- | ----- |
| 123- 56 | 105 | 13 | --- | --- | --- | --- | ----- |
| 123- 5- | 106 | 14 | --- | --- | --- | --- | ----- |
| 123- -6 | 107 | 15 | --- | --- | --- | --- | ----- |
| 123- -- | 108 | 16 | --- | --- | --- | --- | ----- |
| 12- 456 | 109 | 17 | --- | --- | --- | --- | ----- |
| 12- 45- | 110 | 18 | --- | --- | --- | --- | ----- |
| 12- 4- 6 | 111 | 19 | --- | --- | --- | --- | ----- |
| 12- 4- -- | 112 | 20 | --- | --- | --- | --- | ----- |
| 12- - 56 | 113 | 21 | --- | --- | --- | --- | ----- |
| 12- - 5- | 114 | 22 | --- | --- | --- | --- | ----- |
| 12- - - 6 | 115 | 23 | --- | --- | --- | --- | ----- |
| 12- - - - | 116 | 24 | --- | --- | --- | --- | ----- |
| 1- 3456 | 201 | 25 | --- | --- | --- | --- | ----- |
| 1- 345- | 202 | 26 | --- | --- | --- | --- | ----- |
| 1- 34- 6 | 203 | 27 | --- | --- | --- | --- | ----- |
| 1- 34- -- | 204 | 28 | --- | --- | --- | --- | ----- |
| 1- 3- 56 | 205 | 29 | --- | --- | --- | --- | ----- |
| 1- 3- 5- | 206 | 30 | --- | --- | --- | --- | ----- |
| 1- 3- - 6 | 207 | 31 | --- | --- | --- | --- | ----- |
| 1- 3- - - | 208 | 32 | --- | --- | --- | --- | ----- |
| 1- - 456 | 209 | 33 | --- | --- | --- | --- | ----- |
| 1- - 45- | 210 | 34 | --- | --- | --- | --- | ----- |
| 1- - 4- 6 | 211 | 35 | --- | --- | --- | --- | ----- |
| 1- - 4- -- | 212 | 36 | --- | --- | --- | --- | ----- |
| 1- - - 56 | 213 | 37 | --- | --- | --- | --- | ----- |
| 1- - - 5- | 214 | 38 | --- | --- | --- | --- | ----- |
| 1- - - - 6 | 215 | 39 | --- | --- | --- | --- | ----- |
| 1- - - - - | 216 | 40 | --- | --- | --- | --- | ----- |
| - 23456 | 301 | 41 | --- | --- | --- | --- | ----- |
| - 2345- | 302 | 42 | --- | --- | --- | --- | ----- |
| - 234- 6 | 303 | 43 | --- | --- | --- | --- | ----- |
| - 234- -- | 304 | 44 | --- | --- | --- | --- | ----- |
| - 23- 56 | 305 | 45 | --- | --- | --- | --- | ----- |

Point Assignments Cont.

| Popit Switch Setting | Translation | Point # | Point Index | Area Assign | Debounce | BFSK/Relay | Point Text |
|----------------------|-------------|---------|-------------|-------------|----------|------------|------------|
| - 23- 5- | 306 | 46 | --- | --- | --- | --- | ----- |
| - 23- 6 | 307 | 47 | --- | --- | --- | --- | ----- |
| - 23- -- | 308 | 48 | --- | --- | --- | --- | ----- |
| - 2- 456 | 309 | 49 | --- | --- | --- | --- | ----- |
| - 2- 45- | 310 | 50 | --- | --- | --- | --- | ----- |
| - 2- 4- 6 | 311 | 51 | --- | --- | --- | --- | ----- |
| - 2- 4-- | 312 | 52 | --- | --- | --- | --- | ----- |
| - 2- 56 | 313 | 53 | --- | --- | --- | --- | ----- |
| - 2- 5- | 314 | 54 | --- | --- | --- | --- | ----- |
| - 2- --6 | 315 | 55 | --- | --- | --- | --- | ----- |
| - 2- --- | 316 | 56 | --- | --- | --- | --- | ----- |
| --3456 | 401 | 57 | --- | --- | --- | --- | ----- |
| --345- | 402 | 58 | --- | --- | --- | --- | ----- |
| --34- 6 | 403 | 59 | --- | --- | --- | --- | ----- |
| --34-- | 405 | 60 | --- | --- | --- | --- | ----- |
| --3- 56 | 405 | 61 | --- | --- | --- | --- | ----- |
| --3- 5- | 406 | 62 | --- | --- | --- | --- | ----- |
| --3- 6 | 407 | 63 | --- | --- | --- | --- | ----- |
| --3--- | 408 | 64 | --- | --- | --- | --- | ----- |
| ---456 | 409 | 65 | --- | --- | --- | --- | ----- |
| ---45- | 410 | 66 | --- | --- | --- | --- | ----- |
| ---4- 6 | 411 | 67 | --- | --- | --- | --- | ----- |
| ---4-- | 412 | 68 | --- | --- | --- | --- | ----- |
| ---56 | 413 | 69 | --- | --- | --- | --- | ----- |
| ---5- | 414 | 70 | --- | --- | --- | --- | ----- |
| ----6 | 415 | 71 | --- | --- | --- | --- | ----- |
| | | 72 | --- | --- | --- | --- | NOT USED |
| 123456 | 501 | 73 | --- | --- | --- | --- | ----- |
| 12345- | 502 | 74 | --- | --- | --- | --- | ----- |
| 1234- 6 | 503 | 75 | --- | --- | --- | --- | ----- |
| 1234-- | 504 | 76 | --- | --- | --- | --- | ----- |
| 123- 5 6 | 505 | 77 | --- | --- | --- | --- | ----- |
| 123- 5- | 506 | 78 | --- | --- | --- | --- | ----- |
| 123- 6 | 507 | 79 | --- | --- | --- | --- | ----- |
| 123--- | 508 | 80 | --- | --- | --- | --- | ----- |
| 12- 456 | 509 | 81 | --- | --- | --- | --- | ----- |
| 12- 45- | 510 | 82 | --- | --- | --- | --- | ----- |
| 12- 4- 6 | 511 | 83 | --- | --- | --- | --- | ----- |
| 12- 4-- | 512 | 84 | --- | --- | --- | --- | ----- |
| 12- 5 6 | 513 | 85 | --- | --- | --- | --- | ----- |
| 12- 5- | 514 | 86 | --- | --- | --- | --- | ----- |
| 12-- 6 | 515 | 87 | --- | --- | --- | --- | ----- |
| 12--- | 516 | 88 | --- | --- | --- | --- | ----- |
| 1- 3456 | 601 | 89 | --- | --- | --- | --- | ----- |
| 1- 345- | 602 | 90 | --- | --- | --- | --- | ----- |

Point Assignments Cont.

| Poplt Switch Setting | Translation | Point # | Point Index | Area Assign | Debounce | BFSK/Relay | Point Text |
|----------------------|-------------|---------|-------------|-------------|----------|------------|-----------------|
| 1-34-6 | 603 | 91 | --- | --- | --- | --- | ----- |
| 1-34-- | 604 | 92 | --- | --- | --- | --- | ----- |
| 1-3-56 | 605 | 93 | --- | --- | --- | --- | ----- |
| 1-3-5- | 606 | 94 | --- | --- | --- | --- | ----- |
| 1-3-6 | 607 | 95 | --- | --- | --- | --- | ----- |
| 1-3--- | 608 | 96 | --- | --- | --- | --- | ----- |
| 1-456 | 609 | 97 | --- | --- | --- | --- | ----- |
| 1-45- | 610 | 98 | --- | --- | --- | --- | ----- |
| 1-4-6 | 611 | 99 | --- | --- | --- | --- | ----- |
| 1-4-- | 612 | 100 | --- | --- | --- | --- | ----- |
| 1--56 | 613 | 101 | --- | --- | --- | --- | ----- |
| 1--5- | 614 | 102 | --- | --- | --- | --- | ----- |
| 1---6 | 615 | 103 | --- | --- | --- | --- | ----- |
| 1----- | 616 | 104 | --- | --- | --- | --- | ----- |
| -23456 | 701 | 105 | --- | --- | --- | --- | ----- |
| -2345- | 702 | 106 | --- | --- | --- | --- | ----- |
| -234-6 | 703 | 107 | --- | --- | --- | --- | ----- |
| -234-- | 704 | 108 | --- | --- | --- | --- | ----- |
| -23-56 | 705 | 109 | --- | --- | --- | --- | ----- |
| -23-5- | 706 | 110 | --- | --- | --- | --- | ----- |
| -23-6 | 707 | 111 | --- | --- | --- | --- | ----- |
| -23-- | 708 | 112 | --- | --- | --- | --- | ----- |
| -2-456 | 709 | 113 | --- | --- | --- | --- | ----- |
| -2-45- | 710 | 114 | --- | --- | --- | --- | ----- |
| -2-4-6 | 711 | 115 | --- | --- | --- | --- | ----- |
| -2-4-- | 712 | 116 | --- | --- | --- | --- | ----- |
| -2--56 | 713 | 117 | --- | --- | --- | --- | ----- |
| -2--5- | 714 | 118 | --- | --- | --- | --- | ----- |
| -2--6 | 715 | 119 | --- | --- | --- | --- | ----- |
| -2--- | 716 | 120 | --- | --- | --- | --- | ----- |
| -3456 | 801 | 121 | --- | --- | --- | --- | ----- |
| -345- | 802 | 122 | --- | --- | --- | --- | ----- |
| -34-6 | 803 | 123 | --- | --- | --- | --- | ----- |
| --34-- | 804 | 124 | --- | --- | --- | --- | ----- |
| --3-56 | 805 | 125 | --- | --- | --- | --- | ----- |
| --3-5- | 806 | 126 | --- | --- | --- | --- | ----- |
| --3-6 | 807 | 127 | --- | --- | --- | --- | ----- |
| --3--- | 808 | 128 | --- | --- | --- | --- | ----- |
| ---456 | 809 | 129 | --- | --- | --- | --- | ----- |
| ---45- | 810 | 130 | --- | --- | --- | --- | ----- |
| ---4-6 | 811 | 131 | --- | --- | --- | --- | ----- |
| ---4-- | 812 | 132 | --- | --- | --- | --- | ----- |
| ---56 | 813 | 133 | --- | --- | --- | --- | ----- |
| ---5- | 814 | 134 | --- | --- | --- | --- | ----- |
| ----6 | 815 | 135 | --- | --- | --- | --- | ----- |
| | | CMD 9 | | | | | C O M M A N D 9 |
| | | CMD 7 | | | | | C O M M A N D 7 |

Relay Parameters

Area Wide Relays

| | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 |
|-----------------|---|---|---|---|---|---|---|---|
| Alarm Bell ‡ | | | | | | | | |
| Fire Bell ‡ | A | | | | | | | |
| Reset Sensors ‡ | B | | | | | | | |
| Late To Close | | | | | | | | |
| Force Armed | | | | | | | | |
| Watch Mode ‡ | | | | | | | | |
| Area Armed ‡ | | | | | | | | |
| Area Fault | | | | | | | | |
| Duress ‡ | | | | | | | | |
| Keypad Fail* | | | | | | | | |
| Perim Fault | | | | | | | | |
| Silent Alarm | | | | | | | | |
| Command 7 ‡ | | | | | | | | |
| Command 9 ‡ | | | | | | | | |

Panel Wide Relays

| | |
|------------------|--|
| Printer #17 Fail | |
| Printer #18 Fail | |
| Printer #19 Fail | |
| AC Failure | |
| Battery Trouble | |
| Phone Fail | |
| Comm Fail | |
| Log % Full | |
| Summary Fire | |
| Summary Alarm | |
| Summary Fire Tbl | |
| Summary Trouble | |

‡ This symbol indicates the same relay can be shared between areas or functions. A different relay must be used for each area and/or function unless indicated by this ‡ symbol.

*Relay follows the address number for the Command Center.

Relay A = Terminal 6

Relay B = Terminal 7 Requires relay in socket K3

Relay C = Terminal 8 Requires relay in socket K1

| Relay # | Description | Relay # | Description | Relay # | Description | Relay # | Description |
|---------|-------------|---------|-------------|---------|-------------|---------|-------------|
| 1 | | 33 | | 65 | | 97 | |
| 2 | | 34 | | 66 | | 98 | |
| 3 | | 35 | | 67 | | 99 | |
| 4 | | 36 | | 68 | | 100 | |
| 5 | | 37 | | 69 | | 101 | |
| 6 | | 38 | | 70 | | 102 | |
| 7 | | 39 | | 71 | | 103 | |
| 8 | | 40 | | 72 | | 104 | |
| 9 | | 41 | | 73 | | 105 | |
| 10 | | 42 | | 74 | | 106 | |
| 11 | | 43 | | 75 | | 107 | |
| 12 | | 44 | | 76 | | 108 | |
| 13 | | 45 | | 77 | | 109 | |
| 14 | | 46 | | 78 | | 110 | |
| 15 | | 47 | | 79 | | 111 | |
| 16 | | 48 | | 80 | | 112 | |
| 17 | | 49 | | 81 | | 113 | |
| 18 | | 50 | | 82 | | 114 | |
| 19 | | 51 | | 83 | | 115 | |
| 20 | | 52 | | 84 | | 116 | |
| 21 | | 53 | | 85 | | 117 | |
| 22 | | 54 | | 86 | | 118 | |
| 23 | | 55 | | 87 | | 119 | |
| 24 | | 56 | | 88 | | 120 | |
| 25 | | 57 | | 89 | | 121 | |
| 26 | | 58 | | 90 | | 122 | |
| 27 | | 59 | | 91 | | 123 | |
| 28 | | 60 | | 92 | | 124 | |
| 29 | | 61 | | 93 | | 125 | |
| 30 | | 62 | | 94 | | 126 | |
| 31 | | 63 | | 95 | | 127 | |
| 32 | | 64 | | 96 | | 128 | |

Skeds

| Sked # | Function Code | Parameter | | Time | Type 1 | or | Type 2 | Optional | | Description |
|--------|---------------|-----------|----|-------|--------|----------------|--------------|----------|---------|-------------|
| | | 1 | 2 | | Date | Day(s) of Week | Xept Holiday | Holiday | | |
| 01 | 9 | NO | NO | 01:00 | / | | SMTWTFS | Yes / No | 1 2 3 4 | Test Report |
| 02 | | | | | / | | SMTWTFS | Yes / No | 1 2 3 4 | |
| 03 | | | | | / | | SMTWTFS | Yes / No | 1 2 3 4 | |
| 04 | | | | | / | | SMTWTFS | Yes / No | 1 2 3 4 | |
| 05 | | | | | / | | SMTWTFS | Yes / No | 1 2 3 4 | |
| 06 | | | | | / | | SMTWTFS | Yes / No | 1 2 3 4 | |
| 07 | | | | | / | | SMTWTFS | Yes / No | 1 2 3 4 | |
| 08 | | | | | / | | SMTWTFS | Yes / No | 1 2 3 4 | |
| 09 | | | | | / | | SMTWTFS | Yes / No | 1 2 3 4 | |
| 10 | | | | | / | | SMTWTFS | Yes / No | 1 2 3 4 | |
| 11 | | | | | / | | SMTWTFS | Yes / No | 1 2 3 4 | |
| 12 | | | | | / | | SMTWTFS | Yes / No | 1 2 3 4 | |
| 13 | | | | | / | | SMTWTFS | Yes / No | 1 2 3 4 | |
| 14 | | | | | / | | SMTWTFS | Yes / No | 1 2 3 4 | |
| 15 | | | | | / | | SMTWTFS | Yes / No | 1 2 3 4 | |
| 16 | | | | | / | | SMTWTFS | Yes / No | 1 2 3 4 | |
| 17 | | | | | / | | SMTWTFS | Yes / No | 1 2 3 4 | |

Sked Function Code Table

| Function | Parameter 1 | | Parameter 2 | | |
|---|-------------|--|--|-------------|-----------|
| | | Description | Selection | Description | Selection |
| Blank Not In Use (all inactive Skeds must have a Blank entry in Function Code for panel efficiency). | | | | | |
| Arm Area | 1 | Area 1 Area 2 Area 3 Area 4 Area 5 Area 6 Area 7 Area 8 | No / Yes No / Yes No / Yes No / Yes No / Yes No / Yes No / Yes No / Yes | | |
| Disarm Area | 2 | Area 1 Area 2 Area 3 Area 4 Area 5 Area 6 Area 7 Area 8 | No / Yes No / Yes No / Yes No / Yes No / Yes No / Yes No / Yes No / Yes | | |
| Bypass Point A point can be bypassed only if it is programmed to allow bypassing in Point Index. Bypass reports are sent if Report at Occurrence or Defer Bypass Report is Yes for the point. | 3 | Point Number | 1 - 71 / 73 - 135 | | |
| Unbypass Point | 4 | Point Number | 1 - 71 / 73 - 135 | | |
| Unbypass All | 5 | Area 1 Area 2 Area 3 Area 4 Area 5 Area 6 Area 7 Area 8 | No / Yes No / Yes No / Yes No / Yes No / Yes No / Yes No / Yes No / Yes | | |
| Relay On | 6 | Relay Number | 1 - 128 | | |
| Relay Off | 7 | Relay Number | 1 - 128 | | |
| All Relays Off | 8 | None | | | |
| Test Report Generates a test report. The report is sent to the phone(s) programmed in Phone Routing. | 9 | Defer Test | No / Yes | Hourly Rpt | No / Yes |
| Status Report | 10 | Defer Status | No / Yes | | |
| Execute Custom Function | 11 | Cmd Center | 1 - 8 | Custom Func | 128 - 143 |
| Adjust Time Forward 1 Hour Use for Daylight Savings Time adjustments. | 13 | None | | | |
| Adjust Time Backward 1 Hour Use for Daylight Savings Time adjustments. | 14 | None | | | |
| Sound Watch Tone at Command Center | 15 | Command Center Address | 1 - 8 | | |

Holiday Indexes

| Index | | | | Index | | | | Index | | | | |
|-------|---|---|---|-------|---|---|---|-------|---|---|---|---|
| Date | 1 | 2 | 3 | Date | 1 | 2 | 3 | Date | 1 | 2 | 3 | 4 |
| Jan 1 | | | | Feb 1 | | | | Mar 1 | | | | |
| 2 | | | | 2 | | | | 2 | | | | |
| 3 | | | | 3 | | | | 3 | | | | |
| 4 | | | | 4 | | | | 4 | | | | |
| 5 | | | | 5 | | | | 5 | | | | |
| 6 | | | | 6 | | | | 6 | | | | |
| 7 | | | | 7 | | | | 7 | | | | |
| 8 | | | | 8 | | | | 8 | | | | |
| 9 | | | | 9 | | | | 9 | | | | |
| 10 | | | | 10 | | | | 10 | | | | |
| 11 | | | | 11 | | | | 11 | | | | |
| 12 | | | | 12 | | | | 12 | | | | |
| 13 | | | | 13 | | | | 13 | | | | |
| 14 | | | | 14 | | | | 14 | | | | |
| 15 | | | | 15 | | | | 15 | | | | |
| 16 | | | | 16 | | | | 16 | | | | |
| 17 | | | | 17 | | | | 17 | | | | |
| 18 | | | | 18 | | | | 18 | | | | |
| 19 | | | | 19 | | | | 19 | | | | |
| 20 | | | | 20 | | | | 20 | | | | |
| 21 | | | | 21 | | | | 21 | | | | |
| 22 | | | | 22 | | | | 22 | | | | |
| 23 | | | | 23 | | | | 23 | | | | |
| 24 | | | | 24 | | | | 24 | | | | |
| 25 | | | | 25 | | | | 25 | | | | |
| 26 | | | | 26 | | | | 26 | | | | |
| 27 | | | | 27 | | | | 27 | | | | |
| 28 | | | | 28 | | | | 28 | | | | |
| 29 | | | | 29 | | | | 29 | | | | |
| 30 | | | | | | | | 30 | | | | |
| 31 | | | | | | | | 31 | | | | |
| Apr 1 | | | | May 1 | | | | Jun 1 | | | | |
| 2 | | | | 2 | | | | 2 | | | | |
| 3 | | | | 3 | | | | 3 | | | | |
| 4 | | | | 4 | | | | 4 | | | | |
| 5 | | | | 5 | | | | 5 | | | | |
| 6 | | | | 6 | | | | 6 | | | | |
| 7 | | | | 7 | | | | 7 | | | | |
| 8 | | | | 8 | | | | 8 | | | | |
| 9 | | | | 9 | | | | 9 | | | | |
| 10 | | | | 10 | | | | 10 | | | | |
| 11 | | | | 11 | | | | 11 | | | | |
| 12 | | | | 12 | | | | 12 | | | | |
| 13 | | | | 13 | | | | 13 | | | | |
| 14 | | | | 14 | | | | 14 | | | | |
| 15 | | | | 15 | | | | 15 | | | | |
| 16 | | | | 16 | | | | 16 | | | | |
| 17 | | | | 17 | | | | 17 | | | | |
| 18 | | | | 18 | | | | 18 | | | | |
| 19 | | | | 19 | | | | 19 | | | | |
| 20 | | | | 20 | | | | 20 | | | | |
| 21 | | | | 21 | | | | 21 | | | | |
| 22 | | | | 22 | | | | 22 | | | | |
| 23 | | | | 23 | | | | 23 | | | | |
| 24 | | | | 24 | | | | 24 | | | | |
| 25 | | | | 25 | | | | 25 | | | | |
| 26 | | | | 26 | | | | 26 | | | | |
| 27 | | | | 27 | | | | 27 | | | | |
| 28 | | | | 28 | | | | 28 | | | | |
| 29 | | | | 29 | | | | 29 | | | | |
| 30 | | | | 30 | | | | 30 | | | | |
| | | | | 31 | | | | | | | | |

Holiday Indexes Cont.

| Date | Index | | | | Date | Index | | | | Date | Index | | | |
|-------|-------|---|---|---|-------|-------|---|---|---|-------|-------|---|---|---|
| | 1 | 2 | 3 | 4 | | 1 | 2 | 3 | 4 | | 1 | 2 | 3 | 4 |
| Jul 1 | | | | | Aug 1 | | | | | Sep 1 | | | | |
| 2 | | | | | 2 | | | | | 2 | | | | |
| 3 | | | | | 3 | | | | | 3 | | | | |
| 4 | | | | | 4 | | | | | 4 | | | | |
| 5 | | | | | 5 | | | | | 5 | | | | |
| 6 | | | | | 6 | | | | | 6 | | | | |
| 7 | | | | | 7 | | | | | 7 | | | | |
| 8 | | | | | 8 | | | | | 8 | | | | |
| 9 | | | | | 9 | | | | | 9 | | | | |
| 10 | | | | | 10 | | | | | 10 | | | | |
| 11 | | | | | 11 | | | | | 11 | | | | |
| 12 | | | | | 12 | | | | | 12 | | | | |
| 13 | | | | | 13 | | | | | 13 | | | | |
| 14 | | | | | 14 | | | | | 14 | | | | |
| 15 | | | | | 15 | | | | | 15 | | | | |
| 16 | | | | | 16 | | | | | 16 | | | | |
| 17 | | | | | 17 | | | | | 17 | | | | |
| 18 | | | | | 18 | | | | | 18 | | | | |
| 19 | | | | | 19 | | | | | 19 | | | | |
| 20 | | | | | 20 | | | | | 20 | | | | |
| 21 | | | | | 21 | | | | | 21 | | | | |
| 22 | | | | | 22 | | | | | 22 | | | | |
| 23 | | | | | 23 | | | | | 23 | | | | |
| 24 | | | | | 24 | | | | | 24 | | | | |
| 25 | | | | | 25 | | | | | 25 | | | | |
| 26 | | | | | 26 | | | | | 26 | | | | |
| 27 | | | | | 27 | | | | | 27 | | | | |
| 28 | | | | | 28 | | | | | 28 | | | | |
| 29 | | | | | 29 | | | | | 29 | | | | |
| 30 | | | | | 30 | | | | | 30 | | | | |
| 31 | | | | | 31 | | | | | 31 | | | | |
| Oct 1 | | | | | Nov 1 | | | | | Dec 1 | | | | |
| 2 | | | | | 2 | | | | | 2 | | | | |
| 3 | | | | | 3 | | | | | 3 | | | | |
| 4 | | | | | 4 | | | | | 4 | | | | |
| 5 | | | | | 5 | | | | | 5 | | | | |
| 6 | | | | | 6 | | | | | 6 | | | | |
| 7 | | | | | 7 | | | | | 7 | | | | |
| 8 | | | | | 8 | | | | | 8 | | | | |
| 9 | | | | | 9 | | | | | 9 | | | | |
| 10 | | | | | 10 | | | | | 10 | | | | |
| 11 | | | | | 11 | | | | | 11 | | | | |
| 12 | | | | | 12 | | | | | 12 | | | | |
| 13 | | | | | 13 | | | | | 13 | | | | |
| 14 | | | | | 14 | | | | | 14 | | | | |
| 15 | | | | | 15 | | | | | 15 | | | | |
| 16 | | | | | 16 | | | | | 16 | | | | |
| 17 | | | | | 17 | | | | | 17 | | | | |
| 18 | | | | | 18 | | | | | 18 | | | | |
| 19 | | | | | 19 | | | | | 19 | | | | |
| 20 | | | | | 20 | | | | | 20 | | | | |
| 21 | | | | | 21 | | | | | 21 | | | | |
| 22 | | | | | 22 | | | | | 22 | | | | |
| 23 | | | | | 23 | | | | | 23 | | | | |
| 24 | | | | | 24 | | | | | 24 | | | | |
| 25 | | | | | 25 | | | | | 25 | | | | |
| 26 | | | | | 26 | | | | | 26 | | | | |
| 27 | | | | | 27 | | | | | 27 | | | | |
| 28 | | | | | 28 | | | | | 28 | | | | |
| 29 | | | | | 29 | | | | | 29 | | | | |
| 30 | | | | | 30 | | | | | 30 | | | | |
| 31 | | | | | 31 | | | | | 31 | | | | |

System Notes

Printer Address

| Printer | Switches | | | | | |
|---------|----------|-----|----|---|----|----|
| | 1 | 2 | 3 | 4 | 5 | 6 |
| 17 | ON | ON | ON | * | ON | ON |
| 18 | OFF | ON | ON | * | ON | ON |
| 19 | ON | OFF | ON | * | ON | ON |

* ON = Header and Form Feed
 OFF = No Header and Form Feed

Command Center Assignment

| Address # | Switches | | | | | |
|------------|----------|-----|-----|----|----------------------|----|
| | 1 | 2 | 3 | 4 | 5 | 6 |
| Address #1 | ON | ON | ON | ON | ENCODING TONE ON/OFF | ON |
| Address #2 | OFF | ON | ON | ON | | ON |
| Address #3 | ON | OFF | ON | ON | | ON |
| Address #4 | OFF | OFF | ON | ON | | ON |
| Address #5 | ON | ON | OFF | ON | | ON |
| Address #6 | OFF | ON | OFF | ON | | ON |
| Address #7 | ON | OFF | OFF | ON | | ON |
| Address #8 | OFF | OFF | OFF | ON | | ON |

OctoPopit Switch Settings

| Zonex Bus 1 Terminal 27&28 Point 9 - 71 | Switches | | | Zonex Bus 2 Terminal 25&26 Point 73 - 135 |
|---|----------|-----|-----|---|
| | 9 | 10 | 11 | |
| 9 - 16 | ON | ON | ON | 73 - 80 |
| 17 - 24 | ON | ON | OFF | 81 - 88 |
| 25 - 32 | ON | OFF | ON | 89 - 96 |
| 33 - 40 | ON | OFF | OFF | 97 - 104 |
| 41 - 48 | OFF | ON | ON | 105 - 112 |
| 49 - 56 | OFF | ON | OFF | 113 - 120 |
| 57 - 64 | OFF | OFF | ON | 121 - 128 |
| 65 - 71 | OFF | OFF | OFF | 128 - 135 |

OctoRelay Switch Settings

| Zonex Bus 1 Terminal 27&28 Relays 1 - 64 | Switches | | | | Zonex Bus 2 Terminal 25&26 Relays 65 - 128 |
|--|----------|-----|-----|-----|--|
| | 1 | 2 | 3 | 4 | |
| 1 - 8 | OFF | ON | ON | ON | 65 - 72 |
| 9 - 16 | ON | OFF | ON | ON | 73 - 80 |
| 17 - 24 | OFF | OFF | ON | ON | 81 - 88 |
| 25 - 32 | ON | ON | OFF | ON | 89 - 96 |
| 33 - 40 | OFF | ON | OFF | ON | 97 - 104 |
| 41 - 48 | ON | OFF | OFF | ON | 105 - 112 |
| 49 - 56 | OFF | OFF | OFF | ON | 113 - 120 |
| 57 - 64 | ON | ON | ON | OFF | 121 - 128 |



Radionics™

Radionics, 1800 Abbott Street
 Salinas, CA 93901 U.S.A.
 Customer Service: 800-538-5807